

NOTIFICATION OF TEST RESULTS

Issued to: Hager Electro SAS

132 Boulevard d'Europe, 67210 Obernai, France

For the product: Circuit breaker for overcurrent protection

Trade name: HAGER

Type/Model: MC ... * ; MB ... * (* = "...",a,b,c, ,y,z " Country versions)
MCN ... * ; MBN ... * (* = "...",a,b,c, ,y,z " Country versions)
MC ... P ; MB ... P
MU ... * ; MT ... * (* = "...",a,b,c, ,y,z " Country versions)
MUN ... * ; MTN ... * (* = "...",a,b,c, ,y,z " Country versions)
MN ... * ; MM ... * (* = "...",a,b,c, ,y,z " Country versions)
NT ... * (* = "...",a,b,c, ,y,z " Country versions)
MSN ... * (* = "...",a,b,c, ,y,z " Country versions)

Manufactured by: Hager Electro SAS
132 Boulevard d'Europe, 67210 Obernai, France

Ratings: Un = 240 Vac ; 240/415 Vac or 415 Vac;
1 PP, 2 PP, 3 PP, 4 PP, 1 PP + N and 3 PP + N;
Ics=Icn=6 kA; In = 0,5 - 63 A
Characteristic B- and C-curve
ambient temperature 30 °C; 50/60 Hz

Pre-licence factory inspection carried out by
LCIE

**A sample of the product has been tested and found to be in conformity with the
current HD/EN and equivalent national standard**
EN 60898-1:2003, A11:2005, A12:2008, A1:2004

As shown in the Test Report
2144992.50 to .111


This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body, which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

Arnhem, 13 April 2012

Number: NTR NL 6932

DEKRA Certification B.V.


H.L. Schendstok
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

CCA
CENELEC CERTIFICATION AGREEMENT
ACCORD DE CERTIFICATION DU CENELEC

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 352 5800 www.dekra-certification.com Company registration 09085396